



SOUTHERN REGIONAL HIGH SCHOOL DISTRICT

OF OCEAN COUNTY

Drinking Water Testing Results

The school district has completed testing for lead in the drinking water at all school facilities. The testing was conducted at every location that is used for drinking or cooking using guidelines developed by the NJ Department of Environmental Protection and the US Environmental Protection Agency. This testing was completed in August 2016. The results of these tests are attached and indicate that all locations tested are under the threshold limits set by the United States EPA. As a result, no remediation is required within the school district.

The school district will continue to conduct testing annually to insure the safety of the drinking water in our facilities.

If there are any questions regarding the school district's testing protocol please feel free to contact the school district's testing program manager, Dean Adams, at (609)597-9481, extension 4390.

105 CEDAR BRIDGE ROAD, MANAHAWKIN, NJ 08050

PHONE: (609)597-9481, EXTENSION 4209

EMAIL: STERHUNE@SRSD.NET

J.R. HENDERSON LABS, INC.
 123 SEAMAN AVENUE
 BEACHWOOD, NJ 08722-2817
 Certified Lab. I.D #15083

SCHOOL SYSTEM NAME: SOUTHERN REGIONAL DISTRICT

105 CEDAR BRIDGE ROAD

MANAHAWKIN, NJ 08050

SAMPLE DATE: 8/5/16

20 Non-Compliance Samples

PARAMETER: LEAD

Testing Site: 78 MS

CONTACT- HEAD OF MAINTENANCE DEAN ADAMS -609-597-0764

LOCATION	SAMPLE DATE/TIME	ANALYTE NAME	ANALYTICAL METHOD	ANALYSIS DATE/TIME	RESULTS MG/L
MS Nurse	8/6/16 09:00	LEAD	200.9	8/9/16 10:09	<0.001
Main Office DF	8/5/16 09:00	LEAD	200.9	8/9/16 10:13	<0.001
Main Office Kitchen	8/5/16 09:00	LEAD	200.9	8/9/16 10:30	<0.001
ODF by Nurse	8/5/16 09:00	LEAD	200.9	8/9/16 11:02	<0.001
Library Kitchen	8/5/16 09:00	LEAD	200.9	8/9/16 11:06	<0.001
E-4 Sink	8/5/16 09:30	LEAD	200.9	8/9/16 11:10	<0.001
F-5 Sink	8/5/16 09:30	LEAD	200.9	8/9/16 11:14	<0.001
E-3 Sink	8/5/16 09:30	LEAD	200.9	8/9/16 11:19	<0.001
MR Sink	8/5/16 09:30	LEAD	200.9	8/9/16 11:40	<0.001
Cafe DF	8/5/16 09:30	LEAD	200.9	8/9/16 11:44	<0.001
Kitchen Sink	8/5/16 09:30	LEAD	200.9	8/9/16 11:48	<0.001
E-Hall DF by E-5	8/5/16 09:30	LEAD	200.9	8/9/16 11:53	<0.001
E-Hall DF by E-7	8/5/16 09:30	LEAD	200.9	8/9/16 11:56	<0.001
C-Hall DF	8/5/16 09:30	LEAD	200.9	8/9/16 12:18	<0.001
C-12 Sink	8/5/16 09:30	LEAD	200.9	8/9/16 13:40	<0.001
C-15 Sink	8/5/16 10:00	LEAD	200.9	8/9/16 13:45	0.001
C-5 Sink	8/5/16 10:00	LEAD	200.9	8/9/16 13:49	<0.001
C-3 Sink	8/5/16 10:00	LEAD	200.9	8/9/16 13:53	0.002
C-1 Sink	8/5/16 10:00	LEAD	200.9	8/9/16 13:57	0.005
C-6 Sink	8/5/16 10:00	LEAD	200.9	8/9/16 14:02	<0.001

MG/L=Milligrams of contaminant per liter of water equivalent to ppm (parts per million)

Sampled and analyzed as per EPA Testing Schools and Child Care Center for Lead in Drinking Water. (Action Level for Lead is 0.015 mg/l)

J.R. HENDERSON LABS, INC.
 123 SEAMAN AVENUE
 BEACHWOOD, NJ 08722-2817
 Certified Lab. I.D #15083

SCHOOL SYSTEM NAME: SOUTHERN REGIONAL DISTRICT

105 CEDAR BRIDGE ROAD

MANAHAWKIN, NJ 08050

SAMPLE DATE: 8/5/16

10 Non-Compliance Samples

PARAMETER: LEAD

Testing Site: 78 MS

CONTACT- HEAD OF MAINTENANCE DEAN ADAMS -609-597-0764

LOCATION	SAMPLE DATE/TIME	ANALYTE NAME	ANALYTICAL METHOD	ANALYSIS DATE/TIME	RESULTS MG/L
C-4 Sink	8/5/16 10:00	LEAD	200.9	8/9/16 14:06	0.001
C-2 Sink	8/5/16 10:00	LEAD	200.9	8/9/16 14:10	<0.001
D-Hall DF by D-6	8/5/16 10:00	LEAD	200.9	8/9/16 14:15	<0.001
B-1 Sink	8/5/16 10:00	LEAD	200.9	8/9/16 14:59	<0.001
N POD DF	8/5/16 10:00	LEAD	200.9	8/9/16 15:04	<0.001
D-Hall Fac Room	8/5/16 10:00	LEAD	200.9	8/9/16 15:08	<0.001
B-3 Sink	8/5/16 10:00	LEAD	200.9	8/9/16 15:12	0.001
B-5 Sink	8/5/16 10:00	LEAD	200.9	8/9/16 15:17	<0.001
B-7 Sink	8/5/16 10:00	LEAD	200.9	8/9/16 15:21	<0.001
B-11 Sink	8/5/16 10:00	LEAD	200.9	8/9/16 15:25	<0.001

MG/L=Milligrams of contaminant per liter of water equivalent to ppm (parts per million)

Sampled and analyzed as per EPA Testing Schools and Child Care Center for Lead in Drinking Water. (Action Level for Lead is 0.015 mg/l)

J.R. HENDERSON LABS., INC.
 123 SEAMAN AVENUE
 BEACHWOOD, NJ 08722-2817
 732 341-1211
 CERTIFIED LAB: ID # 15083

Southern Regional District - 105 Cedar Bridge Road - Manahawkin, NJ 08050

School Name- 9-10HS

Head of Maintenance: Dean Adams

Report Date: September 8, 2016

Patrick-609 389-5605

Sampled and analyzed as per EPA Testing Schools and Child Care Center for Lead in Drinking Water.

(Action Level for Lead is 0.015 mg/l) Mg/l=milligrams of contaminant per liter of water equivalent to ppm (parts per million)

Sample ID/Location	Sample date / time	Analyte name	Analytical method	Analysis date / time	Results /mg/l
#74 6-2 Sink	8/13/16 17:00	Lead	200.9	8/16/16 13:41	<0.001
#75 6pod DF	8/13/16 17:00	Lead	200.9	8/16/16 13:46	0.001
#76 DF by 1/2way house	8/13/16 17:00	Lead	200.9	8/16/16 13:50	0.015
#77 Sink by 7-6	8/13/16 17:00	Lead	200.9	8/16/16 13:58	0.002
#78 DF by CAF	8/13/16 17:00	Lead	200.9	8/16/16 14:02	<0.001
#79 DF CAF	8/13/16 17:00	Lead	200.9	8/16/16 12:20	0.004
#80 Kltchen	8/13/16 17:00	Lead	200.9	8/16/16 12:25	<0.001
#81 Room 1-2 slnk	8/13/16 17:00	Lead	200.9	8/16/16 12:29	<0.001
#82 Room 1-1 slnk	8/13/16 17:00	Lead	200.9	8/16/16 12:33	<0.001
#83 Room -4 Sink	8/13/16 17:00	Lead	200.9	8/16/16 12:37	<0.001
#84 1-6 Sink	8/13/16 17:00	Lead	200.9	8/16/16 12:24	<0.001
#85 1-3 outside DF	8/13/16 17:00	Lead	200.9	8/16/16 12:46	0.001
#86 Sink 1-3	8/13/16 17:00	Lead	200.9	8/16/16 12:50	<0.001
#87 Sink 8-1	8/13/16 17:00	Lead	200.9	8/16/16 13:07	0.003
#88 Sink 8-1 prep	8/13/16 18:00	Lead	200.9	8/16/16 13:39	0.003
#89 slnk 8-2	8/13/16 18:00	Lead	200.9	8/16/16 13:43	0.001
#90 2 pod DF	8/13/16 18:00	Lead	200.9	8/16/16 13:48	0.001
#91 8-3 Sink	8/13/16 18:00	Lead	200.9	8/16/16 13:52	0.001
#92 8-3 prep Sink	8/13/16 18:00	Lead	200.9	8/16/16 13:56	0.003
#93 8 4 sink prep	8/13/16 18:00	Lead	200.9	8/16/16 14:13	0.003
#94 DF outside 8-4	8/13/16 18:00	Lead	200.9	8/16/16 14:18	<0.001
#95 DF outside 8-5	8/13/16 18:00	Lead	200.9	8/16/16 14:26	<0.001
#96 Sink in 8-5	8/13/16 18:00	Lead	200.9	8/16/16 14:30	0.003
#97 Sink in 8-6	8/13/16 18:00	Lead	200.9	8/16/16 14:30	0.002
#98 Sink in 8-6 prep	8/13/16 18:00	Lead	200.9	8/16/16 15:03	0.004

J.R. HENDERSON LABS., INC.
 123 SEAMAN AVENUE
 BEACHWOOD, NJ 08722-2817
 732 341-1211
 CERTIFIED LAB: ID # 15083

Southern Regional District - 105 Cedar Bridge Road - Manahawkin, NJ 08050

School Name- 9-10HS

Head of Maintenance: Dean Adams

Report Date: September 8, 2016

Patrick-609 389-5605

Sampled and analyzed as per EPA Testing Schools and Child Care Center for Lead In Drinking Water.

(Action Level for Lead is 0.015 mg/l) Mg/l=milligrams of contaminant per liter of water equivalent to ppm (parts per million)

Sample ID/Location	Sample date / time	Analyte name	Analytical method	Analysis date / time	Results /mg/l
# 99 Sink In 8-7	8/13/16 18:00	Lead	200.9	8/17/16 15:20	0.003
#100 DF In 4 good	8/13/16 18:00	Lead	200.9	8/17/16 15:24	<0.001
#101 Sink In 8-8	8/13/16 18:00	Lead	200.9	8/17/16 15:29	0.002
#102 Sink In 8-8 prep	8/13/16 18:00	Lead	200.9	8/17/16 15:33	0.005
#103 Sink In 8-9	8/13/16 18:00	Lead	200.9	8/17/16 15:37	0.001
#104 Sink 810	8/13/16 18:00	Lead	200.9	8/17/16 15:20	0.003
#105 Sink 810 prep	8/13/16 18:00	Lead	200.9	8/16/16 15:24	0.002
#106 Sink 811	8/13/16 18:00	Lead	200.9	8/16/16 15:29	0.002
#107 Room 5-0 sink	8/13/16 18:00	Lead	200.9	8/16/16 15:33	<0.001
#108 Lib Sink	8/13/16 18:00	Lead	200.9	8/16/16 15:37	<0.001
#109 Nurse Sink	8/13/16 18:00	Lead	200.9	8/16/16 16:44	0.001
#110 1DF outside Aud	8/13/16 18:00	Lead	200.9	8/16/16 16:48	<0.001
#111 DF outside Music hall	8/13/16 18:00	Lead	200.9	8/16/16 16:52	<0.001
#112 M4 Sink	8/13/16 18:00	Lead	200.9	8/16/16 16:57	<0.001
#113 DF outside Guldance	8/13/16 18:00	Lead	200.9	8/16/16 17:01	<0.001
#114 DF outside Girls C	8/13/16 18:00	Lead	200.9	8/17/16 17:05	<0.001
#115 Sink 9-12	8/13/16 18:00	Lead	200.9	8/17/16 17:22	<0.001
#116 Sink 9-11	8/13/16 19:00	Lead	200.9	8/17/16 17:27	<0.001
#117 Sink 9-10	8/13/16 19:00	Lead	200.9	8/17/16 17:31	<0.001
#118 Sink 9-9	8/13/16 19:00	Lead	200.9	8/17/16 18:03	<0.001
#119 Sink 9-6	8/13/16 19:00	Lead	200.9	8/17/16 18:07	<0.001
#120 Sink 9-5	8/13/16 19:00	Lead	200.9	8/17/16 18:11	<0.001
#121 Sink 9-3	8/13/16 19:00	Lead	200.9	8/17/16 18:29	<0.001
#122 Sink 9-4	8/13/16 19:00	Lead	200.9	8/17/16 18:33	<0.001
#123 DF In 9pod by 9-4	8/13/16 19:00	Lead	200.9	8/17/16 18:37	<0.001

J.R. HENDERSON LABS., INC.

123 SEAMAN AVENUE

BEACHWOOD, NJ 08722-2817

732 341-1211

CERTIFIED LAB: ID # 15083

Southern Regional District - 105 Cedar Bridge Road - Manahawkin, NJ 08050

School Name- 1112HS

Head of Maintenance: Dean Adams

Report Date: September 8, 2016

Patrick-609 389-5605

Sampled and analyzed as per EPA Testing Schools and Child Care Center for Lead in Drinking Water.

(Action Level for Lead is 0.015 mg/l) Mg/l=milligrams of contaminant per liter of water equivalent to ppm (parts per million)

Sample ID/Location	Sample date / time	Analyte name	Analytical method	Analysis date / time	Results /mg/l
#49 106	8/13/16 15:00	Lead	200.9	8/16/16 09:40	<0.001
#50 DF by 113	8/13/16 15:00	Lead	200.9	8/16/16 09:44	<0.001
#51 DF by CST	8/13/16 15:00	Lead	200.9	8/16/16 09:48	<0.001
#52 Sink in CST	8/13/16 15:00	Lead	200.9	8/16/16 09:52	<0.001
#53 Sink in 104	8/13/16 15:00	Lead	200.9	8/16/16 10:10	<0.001
#54 Sink in 103	8/13/16 15:00	Lead	200.9	8/16/16 10:42	<0.001
#55 Sink in 101	8/13/16 15:00	Lead	200.9	8/16/16 10:45	<0.001
#56 Sink in the Lounge caf	8/13/16 15:00	Lead	200.9	8/16/16 10:50	<0.001
#57 Sink in 229	8/13/16 15:00	Lead	200.9	8/16/16 10:54	0.008
#58 Sink in 229 prep	8/13/16 16:00	Lead	200.9	8/16/16 10:59	<0.001
#59 Sink 228	8/13/16 16:00	Lead	200.9	8/16/16 11:16	0.002
#60 DF by 227	8/13/16 16:00	Lead	200.9	8/16/16 11:20	<0.001
#61 Sink 227	8/13/16 16:00	Lead	200.9	8/16/16 11:24	0.002
#62 Sink 226	8/13/16 16:00	Lead	200.9	8/16/16 11:29	0.001
#63 Sink 227 prep	8/13/16 16:00	Lead	200.9	8/16/16 11:33	0.002
#64 DF by 225	8/13/16 16:00	Lead	200.9	8/16/16 12:05	<0.001
#65 Sink room 225	8/13/16 16:00	Lead	200.9	8/16/16 12:22	0.001
#66 Sink prep 225	8/13/16 16:00	Lead	200.9	8/16/16 12:26	<0.001
#67 Sink 224	8/13/16 16:00	Lead	200.9	8/16/16 12:31	0.001
#68 223 prep	8/13/16 16:00	Lead	200.9	8/16/16 12:35	0.001
#69 Sink 223	8/13/16 16:00	Lead	200.9	8/16/16 12:39	<0.001
#70 Sink 222	8/13/16 16:00	Lead	200.9	8/16/16 12:44	<0.001
#71 Sink 222 Office	8/13/16 16:00	Lead	200.9	8/16/16 12:48	<0.001
#72 Sink 221	8/13/16 16:00	Lead	200.9	8/16/16 12:52	<0.001
#73 DF by 213	8/13/16 16:00	Lead	200.9	8/16/16 12:57	<0.001

J.R. HENDERSON LABS, INC.
 123 SEAMAN AVENUE
 BEACHWOOD, NJ 08722-2817
 Certified Lab. I.D #15083

SCHOOL SYSTEM NAME: SOUTHERN REGIONAL DISTRICT

105 CEDAR BRIDGE ROAD

MANAHAWKIN, NJ 08050

SAMPLE DATE: 8/5/16

17 Non-Compliance Samples

PARAMETER: LEAD

Testing Site: 11 – 12 HS

CONTACT- HEAD OF MAINTENANCE DEAN ADAMS -609-597-0764

LOCATION	SAMPLE DATE/TIME	ANALYTE NAME	ANALYTICAL METHOD	ANALYSIS DATE/TIME	RESULTS MG/L
Nurse	8/5/16 11:00	LEAD	200.9	8/9/16 15:47	<0.001
107 Sink	8/5/16 11:00	LEAD	200.9	8/9/16 15:55	<0.001
Drink F by 108	8/5/16 11:00	LEAD	200.9	8/9/16 16:23	<0.001
DF by Nurse	8/5/16 11:00	LEAD	200.9	8/9/16 16:27	<0.001
DF by 208	8/5/16 11:00	LEAD	200.9	8/9/16 16:32	<0.001
2 nd Floor Fac Rm	8/5/16 11:00	LEAD	200.9	8/9/16 16:53	<0.001
Library Office	8/5/16 11:00	LEAD	200.9	8/9/16 16:57	<0.001
DF Library	8/5/16 11:00	LEAD	200.9	8/9/16 17:02	<0.001
DF by 102	8/5/16 11:00	LEAD	200.9	8/9/16 17:06	<0.001
Room 122	8/5/16 11:30	LEAD	200.9	8/9/16 17:10	<0.001
Kltchen	8/5/16 11:30	LEAD	200.9	8/9/16 17:15	<0.001
DF Caf	8/5/16 11:30	LEAD	200.9	8/9/16 17:19	0.002
DF Weight Room	8/5/16 11:30	LEAD	200.9	8/9/16 18:09	<0.001
DF Gym Hallway	8/5/16 11:30	LEAD	200.9	8/9/16 18:13	<0.001
DF Wrestling Rm	8/5/16 11:30	LEAD	200.9	8/9/16 18:17	<0.001
DF Girls Locker	8/5/16 11:30	LEAD	200.9	8/9/16 18:22	<0.001
DF Boys Locker	8/5/16 11:30	LEAD	200.9	8/9/16 18:26	<0.001

MG/L=Milligrams of contaminant per liter of water equivalent to ppm (parts per million)

Sampled and analyzed as per EPA Testing Schools and Child Care Center for Lead in Drinking Water. (Action Level for Lead is 0.015 mg/l)

